# **RESET:** A Tool to Evaluate Renewable Energy Storage Options

Rebecca Hausheer, Kurt Heinze, Sheena Katai, Karly Kaufman, Jefferson Litten & Gomati Madaiah Bren School of Environmental Science & Management, University of California, Santa Barbara

In the last few decades, the drawbacks of fossil fuel and price volatility-have become increasingly prominent. One way to reduce fossil fuel dependency is to harness the earth's renewable energy resources, such as solar and wind power, and turn them into usable electricity. However, limited by intermittency and variability of solar and wind resources—electrical generation can only occur when the wind blows or the sun shines. Energy storage addresses this limitation by allowing electricity to be stored for use later

Energy storage involves the conversion of electrical energy into another form such as chemical, kinetic or potential energy. The energy can then be stored and then converted back to electrical energy when the electricity is needed. Leading energy storage technologies include batteries, fly-wheels, compressed air storage and pumped hydro.

(see Figure 1). Energy storage can offer economic benefits from applications such as peak shaving or load shifting. However, these benefits must be compared against the and insurance. Prior to this project, no comprehensive tool existed for electricity customers to evaluate energy storage options.



Figure 1: Storage Decision Conceptual Model. If an electricity customer generates excess electricity, the customer may either sell that excess back to the utility (if eligible) or opt to store it.

Fourteen energy storage technologies are analyzed within the RESET framework. The costs and operational characteristics of the included energy storage technologies-both of which change according to the size of the required system—are used to determine the optimal size of the energy storage system required to meet the client's needs. First, RESET calculates the excess electrical generation that would be available for energy storage. Next, RESET maximizes the net present value of each energy storage technology, determining the optimally sized system for storing the available excess. The results are displayed graphically and in tabular form—allowing the user to compare the optimal capacity and net present value for all fourteen technologies.



		_										
nergy Storage Engagement Tool												
n: Solar PV Select from list												
er: Los Angeles Dept of Water & Power (LADWP) Select from list This changes the terminology used by the tool												
horo (in	kW/b.											
<u>)0</u>	<u>2:00</u>	<u>3:00</u> <u>4:00</u>	<u>0 5:00</u>	<u>6:00</u>	<u>7:00</u>	<u>8:00</u>	<u>9:00</u>	<u>10:00</u>				
.4	412.4	410.6 492.0	5 566.8	686.3	781.2	904.3	948.0	969.0				
.4	406.0	403.3 492.2	1 576.0	709.4	867.2	1043.4	1115.7	1157.0	1.000			
.6 a	416.0 401.8	413.1 501.	7 573.2	714.0 623.1	868.9 760.0	1057.9 943 1	1147.2 1034.0	1205.0				
.2	394.9	401.5 400	5	023.1	700.0	545.1	1054.0	1005.5	_			
.1	399.3	Electricity rates (\$/kWh)										
.6 6	421.1 414.6	Current year aver	Current year average during each rate period:									
.3	448.0	High Season		0.04		0.21	Bass	0.11				
.9	422.0	Low Season	Hign-реак	0.94	Low-реак	0.21	Base	0.11				
.3 6	423.1 450 9	Low Season	High-peak	0.23	Low-peak	0.12	Base	0.10				
.0 74	417.50			0.23	Low-peak	0.12	Dase	0.10				
0	0	Energy credit rate	es (if applicable):									
0	0		High-peak	0.00	Low-peak	0.00	Base	0.00				
0	0	Stand Energy Us	ana (01) during a	ach rata nari	a di							
~	0	High Season	age (%) during e	ach rate pen	00:							
0	0	-	High-neak	0%	Low-peak	75%	Base	25%	100%			
0	0	Low Season	підп-реак	076	Low-peak	7570	Dase	2370	10076			
0	0	2011 Ocuson	High-neak	0%	Low-peak	100%	Base	0%	100%			
0	0		Пап-реак	078	Low-peak	10078	Dase	078	10070			
0	0											
00	0.00	Storage Operation										
		Storage operating days: Weekdays only Select from list										
		Operating time per day: 4 hrs Operating days per year: 261 days										
		Duration of storage: 4 – 8 hrs Select from list										
		Other relevant rates & factors										
	Discount rate: 10.0%											
		ſ										
	Annual electricity demand growth rate: 0.0% Annual electricity price growth rate: 2.8%											
		Renewable	generation					-				
			factor:	1 Mu	itiplier for gene	eration profile	(for current g	eneration us	e "1")			
		Carbon Price (\$/r	netric ton): \$	- Opt	tional							
>		eGrid	d subregion CAN	IX – WECC Ca	alifornia	0.31 kg (	CO2e/kWh					
		Geological conditions present for:										
		Geological conditions present for:										
		Pumped Hydro Unknown Compressed Air (CAES) Unknown										
			Opti	mize								
				~					×			

RESET was used to evaluate energy storage options for Los Angeles Harbor College, a 10,000-student community college with a 2.1 megawatt (MW) solar photovoltaic generation system. Harbor College presented to our group two main problems:

Based on Harbor College's existing generation and demand profiles, RESET calculated that sized storage capacity was 0 kilowatt-hours for all technologies (see Figure 2). In other words, the potential savings in avoided future energy bills do not exceed the costs any energy storage system. However, by increasing solar generation capacity or reducing demand through efficiency, energy storage may become a more costeffective option at Harbor College.

**Flooded Cell** Valve Regulat Nickel Cadmi Zinc Bromine Sodium Sulfu Lithium-Ion I Vanadium Re

Figure 2: RESET Results for Harbor College. The optimal storage and net present value for all technologies were zero. Assuming a moderate size energy storage system of 500 kWh, net present values were all negative.

Though in this case study, storage was not profitable—our analysis demonstrates how energy storage can make emissionfree, renewable generation available during all hours of the day. With further innovation and economies of scale, the costs of energy storage technologies will eventually fall, making energy storage coupled with renewable generation a more feasible option for electricity customers across the nation. Renewable generation and energy storage in tandem can help replace fossilfuel based electrical generation. It is our hope that RESET will allow all users to better understand the benefits of energy storage and aid in the path towards a clean energy future.



## **CASE STUDY**

1. Harbor College lacks the metering equipment to measure any excess electricity generation that may exist from their solar array

2. Because Harbor College's solar generation capacity exceeds a

threshold set by their utility, Harbor College is not eligible to receive compensation for excess electricity sent back to the grid.



Given these problems, we used RESET to first calculate Harbor College's excess generation and then evaluate the optimal storage technology and capacity for the campus.

### RECOMMENDATIONS

Technology	Optimal Capacity	Optimal NPV	NPV, 500kWh	
ead-Acid Batteries	0	\$0	-\$213,749	
ed Lead-Acid Batteries	0	\$0	-\$272,411	
m Batteries	0	\$0	-\$900,965	
Flow Batteries	0	\$0	-\$380,285	
Batteries	0	\$0	-\$896,305	
atteries	0	\$0	-\$1,163,320	
lox Flow Batteries	0	\$0	-\$700,730	

## **CONCLUSIONS**